

# LAKE SHORE CENTRAL SCHOOLS

EVANS-BRANT CENTRAL SCHOOL DISTRICT  
DISTRICT OFFICE: 959 BEACH ROAD, ANGOLA, NEW YORK 14006-9782

All Schools 716-549-2300  
Fax 716-549-6407  
www.lakeshorecsd.org

*On Beautiful Lake Erie*

**SENIOR HIGH**  
959 BEACH ROAD  
ANGOLA, NY 14006-9782  
716-926-2307  
FAX 716-549-4033

**MIDDLE SCHOOL**  
8855 ERIE ROAD  
ANGOLA, NY 14006-9624  
716-926-2400  
FAX 716-549-4374

**ANTHONY J. SCHMIDT**  
9455 LAKE SHORE ROAD  
ANGOLA, NY 14006-9400  
716-926-2350  
FAX 716-549-4428

**HIGHLAND**  
6745 ERIE ROAD  
DERBY, NY 14047-9698  
716-926-2460  
FAX 716-947-9269

**JOHN T. WAUGH**  
100 HIGH STREET  
ANGOLA, NY 14006-1300  
716-926-2370  
FAX 716-549-2380

**TRANSPORTATION**  
8710 N. MAIN STREET  
ANGOLA, NY 14006-9603  
716-926-2240  
FAX 716-549-4369

**W. T. HOAG EDUC. CENTER**  
42 SUNSET BOULEVARD  
ANGOLA, NY 14006-1000  
716-926-2480  
FAX 716-549-4391

December 8, 2016

Dear Transportation Department Staff:

It is a priority of every school district to maintain a safe and healthy learning environment for its staff & students, and clean water is no exception. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead and restricted the lead content of faucets, pipes, and other plumbing materials. Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. New laws that went into effect in 2014 reduced the amount of lead that plumbing fixtures can contain from 8% to 1%. Brass faucets, fittings and valves – including those advertised as “lead free” – may still contribute lead to drinking water.

The Lake Shore Central District is in compliance with New York State Public Health Laws requiring all schools and Boards of Cooperative Educational Services (BOCES) to test potable water outlets for lead contamination, to remediate contamination where found, and to notify parents of children and the public of test results. Levels of lead at any water outlet above 15 parts per billion (ppb) require action to remediate this issue.

As required, the Lake Shore Central District tested all water sources in the Lake Shore Central Schools Bus Garage for lead on October 23, 2016. As provided to us under specific protocols, first draw water samples were taken after letting the water remain unmoving in the pipes over a period of 8 to 18 hours. The results of this testing were received on December 8, 2016 and of the 19 water samples tested, only 1 showed lead levels above the 15 ppb mark.

Listed below is the area that exceeded the threshold of 15 ppb:

<b>Locations of Samples Analyzed at or above the NYS Action Level of 15 parts per billion</b>			
Sample #	Classroom or other Location	Outlet type	Laboratory Analysis
104.7-19	2 <sup>nd</sup> Floor, Office	Sink	25.0


The Lake Shore Central School District is taking a number of steps to correct the problems noted. We have shut off the water supply to those fixtures used for drinking or cooking. Any water sources used for other purposes such as washing and general cleaning have been clearly labeled with warning signs not to be used for drinking or cooking. The next step is to develop a remediation plan that will be approved and guided by the experts in the field of water remediation. Please be assured that adequate water fountains are available throughout the building for student use.

The timetable for remediation of each of the identified sources will depend on the availability of parts, installation, and the process for retesting. It is important to note that none of the sources will be put back into service and available for drinking or cooking until the sources are fully mitigated and meet New York State Department of Health Standards.

A copy of the water testing results is available in the main office of the Transportation Department, which is open Monday through Friday from 5:30 am to 5:00 pm. Results are also posted on the District website at [www.lakeshorecsd.org](http://www.lakeshorecsd.org).

For more information about water quality and sampling for lead contact the Erie County Department of Health at 961-6800.

Sincerely,

A handwritten signature in black ink, reading "James E. Przepasniak". The signature is written in a cursive style with a large, looping initial "J".

James E. Przepasniak  
Superintendent of Schools