

---

## Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
AJ Schmidt Elementary	5/27/2021	44	30	14	N/A	N/A

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listing of Outlets Requiring Remediation

#### Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
109.5-3	Room 122 Sink	Sink	21.6
109.5-4	Room 123 Sink	Sink	17.7
109.5-6	Room 121 Sink	Sink	20.6
109.5-8	Room 119 Sink	Sink	24.0
109.5-9	Room 116 Sink	Sink	17.9
109.5-11	Room 114 Sink	Sink	17.9
109.5-21	Room 115	Sink	23.0
109.5-28	Room 148 Kettle Fill	Sink	1810
109.5-29	Gym Storage Area Sink	Sink	18.8
109.5-31	Bathroom in Room 125	Sink	28.4
109.5-32	Bathroom in Room 124	Sink	22.3
109.5-33	Room 124 Office Sink	Sink	17.3
109.5-43	Room 107 Bathroom	Sink	23.8
109.5-57	Room 101 Sink	Sink	15.7